



कार्यालय अधिशासी अभियन्ता, अनुरक्षण खण्ड, उत्तराखण्ड जल संस्थान
लेन नं०-1, तरुण विहार, मोथरो वाला रोड, देहरादून-248001.
Phone No. 0135 2532509, Email- eemdujs@rediffmail.com

पत्रांक- 4926 / ऋषिकेश / 2021-22

दिनांक- 29.03.22

प्रेषित

प्रधानाचार्य,
श्री साई बाबा, इंटरनेशनल,
पब्लिक स्कूल, छिदरवाला,
पो०ओ०-सत्यानारायण,
हरिद्वार हाईवे डोईवाला
देहरादून।

विषय :- जल स्वच्छता एवं पेय योग्य प्रमाण पत्र के सम्बन्ध में।

उपरोक्त विषयक आपके कार्यालय पत्रांक सं०-एस०एस०डी०आई०पी०एस०/28/2022
दिनांक 15.03.2022 के क्रम में प्रमाणित किया जाता है कि जल संस्थान द्वारा अनुरक्षित छिदरवाला
पेयजल योजना के अन्तर्गत जल संयोजन उपभोक्ता संख्या 005516/RK2046 जो कि श्री साई बाबा,
इंटरनेशनल पब्लिक स्कूल, छिदरवाला के नाम से है, में की जा रही जलापूर्ति पेय योग्य एवं स्वच्छ
है।

(के०सी० पैन्वूली)
अधिशासी अभियन्ता

Principal
Sri Sai Baba International Public School
Chidderwala, Dehradun (U.K.)

Sri Sai Baba International Public School
Chidderwala, Haridwar-Dehradun Highway
P.O. - Satyanarayan-249204, Dehradun
Uttarakhand.

कार्यालय मुख्य चिकित्सा अधिकारी, देहरादून


105 बन्दरनगर, देहरादून, दूरभाष संख्या-0135-2724506 फ़ैक्स-2726256, ईमेल- emodehradoon@gmail.com

पत्रांक: -एफ0एस0ओ0 / स्व0प्र0पत्र / 2019 / 240

दिनांक: 20 अप्रैल, 2019


-: स्वच्छता प्रमाण-पत्र :-

प्रमाणित किया जाता है कि श्री रमेश सिंह, खाद्य सुरक्षा अधिकारी की निरीक्षण आख्या दिनांक 17.04.2019 के अनुसार श्री साई बाबा इन्टरनेशनल पब्लिक स्कूल, छिदरवाला, हरिद्वार-देहरादून हाईवे, पो0ओ0 सत्यनारायण, देहरादून का परिसर केन्द्रीय/राज्य सरकार द्वारा निर्धारित मापदण्डों के अनुसार स्वच्छता एवं सफाई की दृष्टि से संतोषजनक पाया गया तथा पानी साफ, शुद्ध एवं मानव उपभोग के लिये उपयुक्त पाया गया।




Principal

Sri Sai Baba International Public School
Chidderwala, Dehradun (U.K.)



मुख्य चिकित्सा अधिकारी,
देहरादून।
Chief Medical Officer
Dehradun



Sri Sai Baba International Public School
Chidderwala, hardwar-dehradun Highway
P.o. - Satyanarayan-249204, dehradun
Uttarakhand.



State Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun
Ph (O): 0135-2746137, E-mail: cenorth-ujs-uk@nic.in

Test Report ID: 1210/UJS/SLWQTML/2021-22

Dated: 16/03/2022

TEST REPORT

Name and Address of Organization/ Customer	Sri Sai Baba International Public School, Chidderwala, P.O. Satyanarayan-249204, Dehradun.		
Product Description (Surface Water/ Ground Water/ Drinking Water)	Drinking Water	Sample Description	One Water Sample collected from Sri Sai Baba International Public School
Reference Sample Identification:	SLWQTML/UJS/SS-01		Date of Start of Analysis: 15/03/2022 Date of End of Analysis: 16/03/2022
Date and Time of Sample Received: 15/03/22&1:45PM	Sample Collected by:		Customer

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	Chloride, mg/L, <i>Max</i>	6.9	250	1000	IS 3025 (Part 32): 1988, RA: 2019 Argentometric Method
2.	Residual Free Chlorine, mg/L, <i>Min</i>	Less than 0.2	0.2	1.0	APHA 23rd Ed.-4500-Cl-G
3.	Colour, Hazen, <i>Max</i>	Less than 05	5	15	IS 3025 (Part 4): 2021 Platinum Cobalt (Visual Comparison)
4.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8) : 1984, RA:2017
5.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5) : 2018
Bacteriological Parameters					
6.	Total Coliform, MPN/ 100ml	Absent	Absent	Absent	APIA 23rd Ed.-9223-B
7.	<i>E. coli</i> , MPN/ 100ml	Absent	Absent	Absent	APIA 23rd Ed.-9223-B

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.

Principal

Sri Sai Baba International Public School
Chidderwala, Dehradun (U.K.)

Sri Sai Baba International Public School
Chidderwala, Haridwar-dehradun Highway
P.O. - Satyanarayan-249204, Dehradun
Uttarakhand.

Vikash Kandari
16/3/22
(Dr. Vikash Kandari)

—End of Report—

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.



State Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun
Ph (O): 0135-2746137, E-mail: eenorth-ujs-uk@nic.in



TC-5372

URL No.: TC537218000000882F

Test Report ID: 1209/UJS/SLWQTML/2021-22


Dated: 16/03/2022

TEST REPORT

Name and Address of Organization/ Customer	Sri Sai Baba International Public School, Chidderwala, P.O. Satyanarayan-249204, Dehradun.		
Product Description (Surface Water/ Ground Water/ Drinking Water)	Drinking Water	Sample Description	One Water Sample collected from Sri Sai Baba International Public School
Reference Sample Identification:	SLWQTML/UJS/SS-01	Date of Start of Analysis:	15/03/2022
		Date of End of Analysis:	16/03/2022
Date and Time of Sample Received: 15/03/22&1:45PM	Sample Collected by:	Customer	

S N	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	pH at 25°C	7.13	6.5 to 8.5	No Relaxation	IS 3025 (Part 11) 1983, RA: 2017: Electrometric method
2.	Total Dissolved Solids (TDS), mg/L, Max	46	500	2000	IS 3025 (Part 16), 1984 RA: 2017: Gravimetric Method
3.	Turbidity, NTU, Max	Less than 01	1	5	IS 3025 (Part 10), 1984, RA:2017: Nephelometric Method
4.	Total Alkalinity (as CaCO ₃), mg/L, Max	32	200	600	IS 3025 (Part 23), 1986 RA: 2019 Titrimetric Method
5.	Total Hardness (as CaCO ₃), mg/L, Max	34	200	600	IS 3025 (Part 21), 2009 RA:2019, (a) EDTA Titrimetric Method
6.	Fluoride, mg/L, Max	Less than 0.2	1.0	1.5	APHA 23rd Ed. 4500-F-D: 2017: SPADNS Method
7.	Nitrate, mg/L, Max	Less than 01	45	No Relaxation	APHA 23rd Ed. 4500-NO ₃ -B:2017: Ultraviolet Spectrophotometric Screening Method
8.	Sulfate, mg/L, Max	Less than 05	200	400	APHA 23rd Ed. 4500-SO ₄ E:2017:Turbidimetric Method

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.


Principal

Sri Sai Baba International Public School
Chidderwala, Dehradun (U.K.)


Sri Sai Baba International Public School
Chidderwala, haridwar-dehradun Highway
P.o. - Satyanarayan-249204, dehradun
Uttarakhand.

(Dr. Vikash Kändari)

-End of Report-

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.